

TEST CERTIFICATE

of the slide-blocking property in wet loaded barefoot areas of floor coverings

Tested material: **Homogeneous Polyvinyl chloride floor covering (PVC)**

Signification: Granit Multisafe
Article-No.: 3476
Dimensions: variable (test unit: 1000 x 500 x 2,0 [mm])
Colour: blue, light- and dark blue spotted
(according to producer indication different colours available)
**Surface: profiled with oval burls (d = 6,3/7,6 mm;
h = 0,6 mm; distance of burls 17,0/14,9 mm)**

Testing object: Arrangement of the profile: with direction.
Delivery of the test material was effected in ready-to-test surface condition.

Producer / Supplier: **Tarkett AB**
Ronnebyhamn
37281 Ronneby
SCHWEDEN

Applicant: Tarkett AB
Ronnebyhamn
37281 Ronneby
SCHWEDEN

Date of order: 26.04.2011

Date of assessment: 19.05.2011

Certificate number: 52061102.001

Sampling: Sent by the customer to the research institute

Test method: **DIN 51097**, ed. 11/92
"Testing of floor coverings; determination of the anti-slip properties; wet-loaded barefoot areas; walking method - ramp test"
Side-blocking Floorings – List NB
"Requirements of the control-committee"

Test result: **Average inclination angle:**
parallel to the length of the burls 26°
cross to the length of the burls 25°

Assessment: **Requirements on the slide-blocking property for the range of application C are fulfilled.**

SÄUREFLIESNER-VEREINIGUNG E. V.
INSTITUTE FOR WALL AND FLOOR COVERINGS
Managing Director

Großburgwedel, 06.07.2011
Schu/FI


Dr.-Ing. Erich H. Nolting

This test-certificate is valid as long as there is no change in the above mentioned test basis - for products which are identical to the test-specimen. The report is given for 5 years (beginning date of assessment). Publication and reproduction of this report is only allowed in unabridged form.

- Institut für Wand- und Bodenbeläge -

SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (05139) 99 82-0 · Telefax (05139) 99 82-40 · E-Mail: info@saeurefliesner.de

Anerkannte Prüf-, Zertifizierungs- und Überwachungsstelle d. DIBT und DIN CERTCO, Berlin · Notifizierte Prüfstelle der Kommission der EU, Brüssel, Kenn-Nr. 1212

