

## **Emission Test Certificate**

Wednesday, 8th October 2014

Supplier: Entegro Group Pty Ltd (15-17 Paw Paw Road, Brooklyn, VIC 3012)

Sample Description: Comcork Flooring

Date Tested: September 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber

Determinations of Organic Emissions from Indoor Material/Products"

**Emission Data:** 

Green Building Council of Australia Green Star Office Design v3 IEQ-13	Comcork Flooring
Total Volatile Organic Compound emission rate: <500 ug/m²/hr	254 ug/m²/hr
4-phenylcyclohexene emission rate:  <50 ug/m²/hr	<6 ug/m²/hr

Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

Nick Joy BSc(Hons)

Consultant

CV140909